





# EPA Sampling and Site IPP Inspections

Friday, September 28, 2018 8:18 AM

Subject	<b>EPA Sampling and Site IPP Inspections</b>
From	Canzano, Joseph
To	bob.weaver@waterandsewer.org
Cc	Canzano, Joseph
Sent	Friday, September 28, 2018 7:59 AM
Attachments	<div> Poly-Metal Finishing ...</div> <div> Poly-Metal Photo Pro...</div> <div> PolyMetals Finishing ...</div> <div> PolyMetals Finishing ...</div>

Good morning Bob – hope all is well for you.

The EPA conducted two industrial user pretreatment inspections at SIUs that discharge into the City's POTW; Poly Metal Finishing, and Chemi-Graphics.

Please find attached a copy the Poly Metal Finishing report w/sampling results and pictures.

EPA detected a total Chromium result of 5.40 mg/l - exceed categorical daily max and monthly average limits in 433.15, and I'm also thinking it exceeded local permit discharge limit.

I would like to discuss with you at your convenience the results, and next step(s).

I will send you the Chemi-Graphics report in a separate e-mail – sample results look ok

I will be the office next week and will try and give you a call.

Thanks.

Joe Canzano, P.E.  
CWA Compliance Coordinator  
US EPA Region 1  
5 Post Office Square  
Suite 100 (OES04-4)  
Boston, MA 02109  
(617) 918-1763  
[canzano.joseph@epa.gov](mailto:canzano.joseph@epa.gov)